

# Water Quality Report for Irrigation

## EFMA Primary Network

Lab results			
Responsible Laboratory: ALS Life Sciences Portugal, S.A.		(Bulletin nº 75736/2023)	Water Quality for Irrigation (annex XVI, DL n.º 236/98)
Parameters	Units	Results	Conformity
Alkalinity	mg/L CaCO <sub>3</sub>	127	
Ammonium	mg/L NH <sub>4</sub>	0,273	
Nitrogen Kjeldahl	mg/L N	0,94	
Total Nitrogen	mg/L N	0,68	
Bicarbonates	mg/L CO <sub>3</sub> H-	155	(a)
Boron	mg/L B	0,0307	●
Calcium	mg/L Ca	39,7	
Chloride	mg/L Cl	48,5	●
Total Hardness	mg/L CaCO <sub>3</sub>	179	
Total Iron (b)	mg/L Fe	0,053	●
Phosphates	mg/L P <sub>2</sub> O <sub>5</sub>	<L.Q.	0,12
Total Phosphorus	mg/L P	<L.Q.	0,05
Magnesium	mg/L Mg	19,5	
Manganese	mg/L Mn	0,0175	●
Nitrates	mg/L NO <sub>3</sub>	<L.Q.	2
Nitrites	mg/L NO <sub>2</sub>	0,0163	●
Potassium	mg/L K	6,2	
Ratio of Sodium Absorption (SAR)		1,259	●
Ratio of Sodium Absorption adjusted (SARaj)		1,315	
Sodium	mg/L Na	38,8	
Total Dissolved Solids (TDS)	mg/L	301	●
Total Suspended Solids (TSS)	mg/L	<L.Q.	3
Sulphates	mg/L CO <sub>4</sub>	33	●
Total Coliforms	NPM/100 mL	10	
Fecal Coliforms	NPM/100 mL	8,2	●

**Note:** With the exception of the SARaj parameter, test to determine the remaining parameters are included in the range of laboratory accreditation.

Field Results (Determined with a multiparameter probe)			
Responsible Laboratory: ALS Life Sciences Portugal, S.A.		(Bulletin nº 75736/2023)	Water Quality for Irrigation (annex XVI, DL n.º 236/98)
Parameters	Units	Results	Conformity
Temperature	°C	14,1	
pH	Escala Sorensen	8,10	●
Conductivity	µS/cm	485	●

- Lower than the VMR (Maximum Value Recommended).
- Higher than VMR and below the VMA (Maximum Permitted Value).
- Higher than VMR. For this parameter is not defined one VMA.
- Higher than the VMA.


(a) The maximum value recommended in the Integrated Production Standards, for most crops, is 90 mg / L.  
(b) The VMA in Annex XVI of the Decree-Law nº 236/98 refers to the dissolved iron (5 mg/L Fe).

Sampling Data: 04/01/2023

Sampling Place: Loureiro

### Benefited areas:

The Loureiro reservoir constitutes the water source of the Monte Novo, Loureiro-Alvito and Évora irrigation perimeters.



### Comments:

The bicarbonate values exceed the maximum value recommended in the Integrated Production Standards. High concentrations of bicarbonates can affect crop yields, making it difficult to absorb some mineral nutrients.

The results of the remaining elements are within the range of expected values for this typology of water bodies.

In the document "Water Quality - Complementary Information", EDIA recommends some general measures to reduce the concentration of salts in the water bodies.