

# Water Quality Report for Irrigation

## EFMA Primary Network

Lab results		Water Quality for Irrigation (annex XVI, DL n.º 236/98)	
Responsible Laboratory: ALS Life Sciences Portugal, S.A.		(Bulletin nº 29070/2025)	
Parameters	Units	Results	Conformity
Alkalinity	mg/L CaCO3	163	
Ammonium	mg/L NH4	0,146	
Nitrogen Kjeldahl	mg/L N	0,73	
Total Nitrogen	mg/L N	0,85	
Bicarbonates	mg/L CO3H-	199	(a)
Boron	mg/L B	0,0333	<div></div>
Calcium	mg/L Ca	45	
Chloride	mg/L Cl	86	<div></div>
Total Hardness	mg/L CaCO3	196	
Dissolved Iron	mg/L Fe	0,008	<div></div>
Phosphates	mg/L P2O5	0,088	
Total Phosphorus	mg/L P	0,038	
Magnesium	mg/L Mg	20,2	
Manganese	mg/L Mn	0,0166	<div></div>
Nitrates	mg/L NO3	<L.Q.	<div></div>
Nitrites	mg/L NO2	0,055	
Potassium	mg/L K	6,6	
Ratio of Sodium Absorption (SAR)		1,33	<div></div>
Ratio of Sodium Absorption adjusted (SARaj)		1,4	
Sodium	mg/L Na	42,9	
Total Dissolved Solids (TDS)	mg/L	406	<div></div>
Total Suspended Solids (TSS)	mg/L	7,3	<div></div>
Sulphates	mg/L CO4	46,6	<div></div>
Total Coliforms	UFC/100 mL	1	
Fecal Coliforms	UFC/100 mL	0	<div></div>

**Note:** With the exception of the SAR<sub>aj</sub> parameter, test to determine the remaining parameters are included in the range of laboratory accreditation.

Field Results (Determined with a multiparameter probe)			Water Quality for Irrigation (annex XVI, DL n.º 236/98) Conformity
Parameters	Units	Results	
Temperature	°C	26,4	
pH	Escala Sorensen	8,60	●
Conductivity	µS/cm	655	●

- Lower than the VMR (Maximum Value Recommended).
- Higher than VMR and below the VMA (Maximum Permitted Value).
- Higher than VMR. For this parameter is not defined one VMA.
- Higher than the VMA.

(a) In the Integrated Production Standards, the previously recommended value for bicarbonates, in most crops, was 90 mg/L.


Sampling Data: 27/06/2025

Sampling Place: Pias

### Benefited areas:

The reservoir of Pias constitutes the water source of the blocks Figueiral Alto and Pias Alto, integrated in the irrigation perimeter of Pias.

The EDIA monitoring program aims to assess the quality of water for irrigation, and does not allow for the assessment of whether the water is suitable for any other use.



### Comments:

The pH result exceeds the Recommended Maximum Value range for water quality for irrigation (VMR: [6.5-8.4]). This may be due to an increase in the biological activity of algae. High pH values can affect the plant's ability to absorb nutrients and promote the precipitation of iron, calcium, magnesium and phosphate ions, which may promote the clogging of drip irrigation systems. Chlorides exceed the VMR for irrigation (70 mg / L) and may originate from natural land drainage or agricultural runoff. At high concentrations they may be toxic to plants and cause deflocculation of soil clays, degrading their structure. The bicarbonates results are higher than the maximum value previously recommended in the Integrated Production Standards. High concentrations of bicarbonates can affect crop yields, making it difficult to absorb some mineral nutrients. The results of the remaining elements are within the range of expected values for this typology of water bodies. In the document "*Water Quality - Complementary Information*", EDIA recommends some general measures to reduce the concentration of salts in the water bodies.